

# Opening Inspection Preparation List

\*The following requirements must be met and in place prior to the opening inspection.

Completed operational permit application.

Operational permit fee (Seasonal:\$300/Year Round:\$450)

\*Certified Pool Contractor must be present at the opening inspection.

\*Must make 100% on the inspection form with no violations of any kind.

Must have approved emergency action plan with required section. Emergency action plan must be placed in conspicuous place for immediate access.

Must have all emergency equipment in place at the time of inspection. Equipment must be in a conspicuous place and mounted. (Sheppard's Hook, 14 ft pole, Ring Buoy with Rope)

Emergency Phone must work and contain sign near phone listing emergency numbers for the Health Department (404 508 7900), certified pool operator, and a person in management.

Must have at least two signs stating "Warning NO lifeguard". One sign near the entrance and another one inside the pool area. \*Only if no life guards will be present.

The pool rule sign must contain ALL the required statements in their required size. Certain statements have larger lettering size requirements.

Must have certified pool operator certification displayed in pool area. Must also have a place to display the inspection report and operational permit. **CPO certification must be current.**

All pool bathrooms must be clean and properly functioning. Sinks must have hot and cold water. Bathrooms must have soap and paper towels.

Pool area and bathroom must have covered and lined trashcans.

Pool pumps, chlorinators, heaters, etc must be on and fully functioning.

Pool chemistry must be within the required range at time of inspection.

First Aid Kit must be mounted within the pool area.

Fence/barrier must be 5 ft. minimum, from grade, in all areas surrounding the pool.

All entry fences into pool area must self-close and latch when opened 4 inches.

The fence can contain no openings larger than 4 inches. This includes between pickets or below the fence.

Pump rooms must be clean, have chemicals off the floor, and contain all required ventilation. (Fan/louvers, etc)

Pump room equipment lines must be labeled by name and direction of flow.

Depth marker tiles must be in minimum 4-inch lettering, black letters, white background.

No diving markers must be in minimum 2-inch lettering, black letters, white background.

Must have log book that will contain the pH and chlorine log readings.

Must have test kit available to test for pH and chlorine.